

To,
The Deputy General Manager,
M/s Navayuga Engineering Company Ltd.,
Behind Orange Hotel,
Village-Kasara,
District Thane, Maharashtra.

Sub: Construction of Access Controlled Nagpur-Mumbai Super Communication Expressway (Maharashtra Samruddhi Mahamarg) in the State of Maharashtra on EPC mode for Construction Package 15, from Km 636.479 to Km 664.479 (Section-Village Vashala Bk to Village Birwadi) in District Thane.

Reg. Submission of Credentials of "M/s ADD CHEM INDUSTRIES" for Source Approval of 'Chemical Admixtures'.

Ref: 1) MSRDC Letter no. MSRDC/NMSCEW/5320/2019 dated 21.08.2019.
2) Your office letter no. NECL/1300/PVK/1922 dated: 17.04.2022.
3) Our office letter no. E/8330/NMSCE/SCG: BRP/NECL/2117 dated 28.04.2022.
4) Your office letter no. NECL/1300/PVK/2026 dated: 04.07.2022.
5) Your office letter no. NECL/1300/PVK/2068 dated: 14.08.2022.
6) Our office letter no. E/8330/NMSCE/SCG: BRP/NECL/2287 dated 25.08.2022.
7) Your office letter no. NECL/1300/PVK/2131 dated: 25.09.2022.

Dear Sir,

With reference to the above mentioned subject and your above referred letter at Sl.no.-(7) along with the submission of required documents (i.e. latest Third Party test report) as Credentials of the **"M/s ADD CHEM INDUSTRIES"**, for the Source Approval of **Chemical Admixtures**, the same has been reviewed and concurred.

The final source concurrence shall be subjected to the factory visit and satisfactory test results of the relevant **Chemical Admixtures** as per the IS: 9103 (latest revision), MSRDC Guidelines, MoRT&H specifications, Contract Agreement and other relevant codes.

Nonetheless, the concurrence of the source of **"M/s ADD CHEM INDUSTRIES"** shall be liable to following anticipated stipulations:

1. Chemical Admixture shall be used in concrete only after successful laboratory trial mix & approval of mix design.
2. Every consignment (Lot) of the relevant **Chemical Admixture** brought to the site shall confirm to IS: 9103, Contract Agreement, MoRT&H specifications, MSRDC Guidelines and other relevant codes and each lot shall be furnished with Manufacturing Test Certificates (MTC) covering all the requisite tests as per the relevant applicable codes.
3. All lots of the material received at site shall be sent to NABL Accredited Lab testing as per the Contract Agreement, MoRT&H specifications and other relevant codes and their results are to be submitted along with MTCs to Authority's Engineer for review.
4. Stacking and Storage shall be done as per the IS: 4082-1996, MoRT&H specifications and other relevant codes.



If any stage if infringement of the specifications or above conditions found then the concurrence shall be revoked.

This is for your information and necessary action at the earliest.

Regards

**For STUP Consultants Pvt. Ltd
(In Association with PEMS Engineering Consultants Pvt. Ltd.)**



S. C. Gupta
Team Leader

Cc: 1) Project Director (CP-15) NMSCEL, Bandra for information please.
 2) Executive Engineer (CP-15) NMSCEL, Bandra for information Please.