



LION ENGINEERING CONSULTANTS PVT. LTD.
Lion Tower, Plot No. 97, Elegant State, Near Mother
Teresa School, Kolar Road, Bhopal – 462042 (M.P.)
Ph: 0755 2879499/3243234/3246437/3242728
email: corporate@liongroup.in

in JV with

TECHNOGEM CONSULTANTS PVT. LTD.
Office 803, 8th floor, B-wing Lodha Supremum II,
Near New Passport Office, Road no. 22,
Wagle Estate, Thane – 400 604
Ph.: 022-49749899 / 49747799
email: technogem@rediffmail.com

LEC/IE/Vad-Tha/NH-848/2024/1777

Date: 16.02.2024

To,
The Project Director (Nodal),
MSRDC Infrastructure Projects Limited,
Opp. Bandra Reclamation Bus Depot,
Near Lilawati Hospital, KC Marg,
Bandra (W), Mumbai-400050
Email: msrdeipl@gmail.com

Sub.: Independent Engineer Services for Construction of 6/8 laning of existing 4 lane Vadape to Thane from Km 539.202 to Km 563.000 section of NH-3 (new NH-848) under Bharatmala Pariyojna in the State of Maharashtra to be executed on Hybrid Annuity Mode – **"In-Principle Approval of M/s. Add Chem Industries for Procurement of Chemical Admixture and Curing Compound"–Reg.**

Ref.: Your Letter No. MSRDC/MIPL/VTR/2024/2683, Dated. 01.02.2024.

Dear Sir,

This is with reference to above cited subject and letter, wherein you have submitted credential of chemical admixture and curing compound of M/s. Add Chem Industries for review and approval of I.E. In this connection, this office same has been reviewed and found satisfactory. Hence, the above manufacturer has been permitted for site trial subject to following condition.

1. Every consignment should be supported with MTC.
2. Before incorporate into permanent work, sample shall be jointly collected and sent to the NABL laboratory.
3. A trial mix should be conducted at site laboratories and report to be submitted.
4. Admixture should be confirmed to the requirement of IS-970, IS-9103-2018 & MoRTH specification.
5. Curing compound shall be resin based aluminized reflective for PQC work in confirmatory to 602.9.12 of MoRTH specification.
6. The packing of admixture shall clearly indicate the name of the manufacturer, name of the product, date & its expiry.
7. Stock/Consumption register of each product shall be maintained and shall be produced.
8. In case of the test result indicates that the materials (Chemical Admixture & Curing Compound) procured don't confirmed to specification the same shall be rejected.

This is for your kind information and necessary action.

Thanking You,

Yours Sincerely,
For Lion Engineering Consultants Pvt. Ltd.
(JV with Technogem & in Association with RSI)

(T. Rayi)
Team Leader

Cc: 1. The Project Director, NHAI, PIU, Thane for information please.

2. The Authorized Signatory, Sr. CGM (Tech/BD), LEC Pvt. Ltd. HO, Bhopal for information.

3. The Executive Director, M/s Technogem Consultants Pvt. Ltd. for information.