



MSV INTERNATIONAL INC.

Pune Office No. 3 & 4, Gurukrupa Building,
Near Maratha Mandir,
Behind Combine Square,
Bavdhan, Pune-411021
Email:-msv.rsipkg5@gmail.com
Contact:-9850974346

Unit No. 514,515 and 516 5th floor Suncity
Success Tower Golf Course Extension Road
Gurgaon- 122005 (Haryana)
Email- info@msvgroup.com
Tel. 0091-124-2841160

Ref: MSV/AE/MSIDC/2024-25/410

Date: 16/04/2025

To,
ISC Projects Pvt. Ltd.
Pune.

Subject : EPC Chandgad - Improvement to Chandgad Ibrahimpur Chitale Shrungarwadi Ajara Burude Honewadi Mahagaon Vairagwadi Hasursasgiri Narewadi Halkarni Khanapur up to District Border SH -201 Km 00/00 to 60/00 Taluka Chandgad Ajara Gadhinglaj District Kolhapur on EPC mode- **Reg: - Source Approval of M/s Add Chem Industries.**

Ref:

1. Work Order. No. – MSIDC/1338/2024/Dt.11/10/2024
2. EPC Contractor Letter No. ISCPPL/MSIDC/CHANDGAD/2024/121, Dated 17/04/2025.

Dear Sir,

With the reference to the above cited subject, that the project requirements and **MSIDC** guidelines, we hereby approve **M/s Add Chem Industries** the use of ("**Crystalline Durability Admixture**") (CDA) (**Superplasticiser**) **Curing compound**, for construction purposes, subject to the following conditions:

1. Upon arrival at the site, the admixture stock shall be sampled and sent for third-party testing at an accredited laboratory. The material shall be used only after receiving satisfactory test results and Credentials.
2. Any other construction material arriving at the site for execution must also undergo third-party testing before use.
3. Admixtures shall confirm to the requirement of the section 1012 of MORT&H and IS: 9103 specification during third party NABL accredited laboratory test.
4. Admixture shall meet the requirement stipulated in clause 5.5 of IS: 456.
5. Compliance with the approved mix design and quality control measures must be ensured at all times.
6. The Final Approval will be processed best on the Performance of the Admixture observed during the actual trail of concrete mix design.

"As per MSIDC guidelines and HAM EPC Tender Agreement (Annexure III) Page No 23 to Page No. 33. The Admixture should be tested at one of the following IIT Bombay, IIT Madras, IIT Hyderabad,



MSV INTERNATIONAL INC.


Pune Office No. 3 & 4, Gurukrupa Building,
Near Maratha Mandir,
Behind Combine Square,
Bavdhan, Pune-411021
Email:-msv.rsipkg5@gmail.com
Contact:-9850974346

Unit No. 514,515 and 516 5th floor Suncity
Success Tower Golf Course Extension Road
Gurgaon- 122005 (Haryana)
Email- info@msvgroup.com
Tel. 0091-124-2841160

IIT Roorkee and CSIR, New Delhi. Material verification should be done from approved brands with their certification as per IRC.

This is for your kind information and necessary action please.

Yours Sincerely


Pradeep K. Tiwari
Team Leader
MSV International Inc. Pune.

Enclosed: Credential of M/s Add Chem Industries.

Copy to:

- 1) The Superintending Engineer, Bakhtawar Building, MSIDC Mumbai-400021
- 2) The Executive Engineer, Bakhtawar Building, MSIDC Mumbai-400021