


## Rodic Consultants Pvt. Ltd. (RCPL)

In JV with





Team Leader Office: AE (Group-8) 3 Srushti apartment 431/1/121 Adarsh Nagar Jalgaon-425001

Letter No. HBT-1648-SO-LTR-2025/0444

Date: 11.04.2025

To.

Authorized Signatory,

ALTIS HOLDINGS Corporation in JV with BNA Infrastructure Pvt.Ltd.

Email: bna.epcprojects@gmail.com.

Name of Work: EPC NSK-II (26 B)- Improvement to Nashirabad Sunasgaon Kurha Bodwad road SH-270 Km.0/00 to 56/550 Tal. Jalgaon, Bhusawal & Bodwad. Dist. Jalgaon. Subject: Submission of Company Profile and Credentials of (Admixture and Crystalline Admixture).

Reference: 1) Your letter no. BNA/MSIDC/26-B/2024-25/86-26B, Dated 14/02/2025.

## Dear Sir,

With reference to the above-mentioned subject and in continuation of your letter under ref (3), wherein you have submitted the credentials and profile of the following Agency for the source approval of Admixture and Crystalline admixture). The name of the Agency is mentioned below.

Name of the Agency

Name of the Products

1) M/s Add Chem Industries.

(Admixture and Crystalline Durable Admixture)

We have reviewed the details of manufacturer credentials. Provisional source approval is accorded with the above-mentioned Agency. However, the acceptance of the product will be subject to the following comments.


- 1) The mixed design trials with the admixture are to be done in the presence of ITF/ AE representative to know the workability and compressive strength of Cubes for various grades of concrete.
- 2) RFI's will be raised for sampling and testing against each lot bearing specific no. giving details of source, lot size with delivery note.
- 3) Manufacture test certificates are required for every consignment material procured.
- 4) Every consignment lot sample should be tested in the independent NABL Laboratory for the



Office RODIC: 1st Floor, YMCA Cultural Center cum Library Building, 1, Jai Singh Road, New Delhi-110001, India E-mail: contact@rodicconsultants.com; Tel.: (+91) 011 4943 4500

## Rodic Consultants Pvt. Ltd. (RCPL)

In JV with





Team Leader Office: AE (Group-8) 3 Srushti apartment 431/1/121 Adarsh Nagar Jalgaon-425001

confirmation of admixture as per IS: 9103, IS 2645 and ASTM C494 Codal provisions.

5) If the admixture will not perform in future as per the specification requirements or if it fails when tested in Independent NABL Laboratory, source approval will be automatically cancelled.

Thanks, & regards

(Sanjay Sharma)

**TEAM LEADER** 

Rodic Consultants Pvt. Ltd. in JV with M/s Geo Designs and Research Pvt. Ltd

CC:1. SE, MSIDC, Nagpur for Information.

2. EE, MSIDC, Amravati for Information.

3. ITF(Civil Tech) for Information.

Office GDRPL: B-10, Krishna Industrial Estate, Opp B.I.D.C., Gorwa Estate, Vadodara - 390 016, Gujarat, India.

E-mail: pmc@geogroup.in; Tel.: (+91) 265-229-0222