



# Sttar Technologies

MECHANICAL | CHEMICAL | NDT | DURABILITY | BITUMEN | SOIL  
Civil Engineering Material Testing Laboratory  
ISO / IEC 17025:2017 NABL Accredited Testing Laboratory  
GSTIN : 27ADWFS8826R1ZL



## TEST REPORT ADMIXTURE


Report No. :	SC/ 152687 / 52648 / C - 8	Inward No	ST/ 52648
ULR No:	TC 125000007555 C	Report issue date	23/10/2024
Issue To:	M/s. ADD CHEM INDUSTRIES, A 506 PRISHA APPARTMENT BEHIND KAMALA ARCADE RABALE NAVI MUMBAI 400701	Date of Receipt	18/10/2024
		Date of start	18/10/2024
		Date of Completion	20/10/2024
		Condition of Sample	Good
Project/Site	M/S. CMV Concrete Pvt.Ltd, L-105, Plot No. 4,5,6 and 7 Yash Paradise, Sector 8A, Airoli Navi Mumbai, Thane : 400708		
Letter Reference	Letter Dated : 15 / 10 / 2024		
Sample Description/ID Mark:	Admixture, Product Name -ACI Plast PC 500 , ADD CHEM INDUSTRIES		
Size/Brand/ Batch No.:	Lot No. F110/0922		
Discipline :	Chemical Testing	Group :	Building Material

### Results And Observations :

Sr.No	Test Parameter	Test Method used	Test Result	Permissible Limit IS:9103-1999 Reaffirmed 2018 (Clause 9)Table 2 & Amendment no.2 Aug 2007
1	Colour	As Per RDSO	light Brown	-
2	pH	IS 9103:1999 Reaffirmed 2018 Clause 10.1 E5	6.78	Min 6
3	Relative Density 20 ± 5°C	IS 9103:1999 Reaffirmed 2018 Clause 10.1 E-3.1	1.090	Within 0.02 of value stated by manufacturer
4	Dry Material Content, %	IS 9103:1999 Reaffirmed 2018 Clause 10.1 E-1	30.24	Within 3% of the value stated by manufacturer
5	Chloride ion content, %	IS 6925:1973 Reaffirmed 2018	NIL	within 10% of value stated by manufacturer or within 0.2% of whichever is greater as stated by manufacturer
6	Ash Content, %	IS 9103:1999 Reaffirmed 2018	3.20	Within 1% of the value stated by manufacturer

### Remark:

1. Test report shall not be reproduced except in full without consent of Sttar technologies.
2. Any correction invalidates this report.
3. The test results reported and report only to the sample tested as submitted by the customer

  
Dhanashri Tambadkar  
Sr. Chemist  
Reviewed By



  
Ashok Raut  
Technical Manager  
Authorized Signatory