



Sttar Technologies

MECHANICAL | CHEMICAL | NDT | DURABILITY | BITUMEN | SOIL
Civil Engineering Material Testing Laboratory
ISO / IEC 17025:2017 NABL Accredited Testing Laboratory
GSTIN : 27ADWFS8826R1ZL



TC-9176

TEST REPORT				
ADMIXTURE				
Report No. :	SC / T / 25687 / 5987 / C-3		Inward No	STOT5987
ULR No.:	TC 026782594141- C 3		Report Issue date	03/01/2025
Issue To:	M/s. ADD CHEM INDUSTRIES. 506, Prisha Apartment, Rabale, Behind Kamala Arcade, Navi Mumbai - 400701		Date of Receipt	01/01/2025
			Date of Start	01/01/2025
			Date of Completion	03/01/2025
			Condition of Sample	Good
Letter Reference:	Letter dated : 02/01/2025			
Name of Customer:	J. M. MHATRE INFRA PVT. LTD.			
Sample Description / ID Mark :	Admixture-ACI MID PC-350			
Size/ Brand/ Batch No.:	ACI MID PC-350			
Discipline	Chemical Testing	Group :	Building Material	
Result And Observation :				
Sr. No.	Test Parameter	Test Method Used	Test Result	Permissible Limit IS:9103-1999 Reaffirmed 20108 (Clause 9) Table 2 & Amendment no. 2 Aug 2007
1	Colour	As per RDSO	Brownish	-
2	pH	IS 9103:1999 Reaffirmed 2018 clause 10.1 E5	7.02	Min 6.0
3	Relative Density 20 ± 5°C	IS 9103:1999 Reaffirmed 2018 clause 10.1 E-3.1	1.174	Within 0.02 of value stated by manufacturer
4	Dry Material Content,%	IS 9103:1999 Reaffirmed 2018 clause 10.1 E-1	32.895	Within 5% of value stated by manufacturer
5	Ash Content %	IS 9103:1999 Reaffirmed 2018	3.25	Within 1% of value stated by manufacturer
6	Chloride ion content,%	IS 6925:1973 Reaffirmed 2018	Nil	Within 10% of value stated by manufacturer or Within 0.2 % of whichever is greater as stated by manufacturer
Remark: 1. Test report shall not be reproduced except in full without consent of Sttar technologies. 2. Any correction invalidation this report. 3. The results apply to the sample as received . 4. The results relate only to the items tested.				
 Aparna Patil Jr. Chemist Reviewed By		 End of Report	 Ashok Raut Technical Manager Authorized Signatory	
AP page1of1		Format No.: ST/FM/TR		

Customer Enquiry Email : sttartechn123@gmail.com / www.sttartechn.com / Billing Enquiry : accts.sttartechnologies@gmail.com

Material Pickup Support +91 8928557803 / Customer Care & Accounts Support +91 8828044808

MD : +91 97686 88099 / 022 6881 1510

Lab : Platinum Springs, B-6, B-101/102, Plot No. G-20 to G-24, Nr. Dena Bank, Tal. Panvel - 410208.



www.iclcert.com



ISO 9001:2015
Rgn. No. IN12648A

UDYAM - MH-33-0155253