



Sttar Technologies

MECHANICAL | CHEMICAL | NDT | DURABILITY | BITUMEN | SOIL
Civil Engineering Material Testing Laboratory
ISO / IEC 17025:2017 NABL Accredited Testing Laboratory
GSTIN : 27ADWFS8826R12L



TC-9176

TEST REPORT				
ADMIXTURE				
Report No. :	ST/C/250833/5889/C-2		Inward No	STOT 5889
UIR No:	TC 256879000551/C-2		Report issue date	28/02/2025
Issue To:	M/s. ADD CHEM INDUSTRIES. 506, Prisha Apartment, Rabale, Behind Kamala Acrede, Navi Mumbai-400701.		Date of Receipt	24/02/2025
			Date of start	24/02/2025
			Date of Completion	28/02/2025
			Condition of Sample	Good
Letter Reference:	Letter dated: 23/02/2025			
Name of customer:	J. M. MHATRE INFRA PVT. LTD.			
Sample Description/ID Mark:	Admixture-ACI PQ C577			
Size/Brand/ Batch No.:	ACI PQC 577			
Discipline :	Chemical Testing	Group :	Building Material	
Results And Observations :				
Sr.No	Test Parameter	Test Method used	Test Result	Permissible Limit (IS:9103-1999 Reaffirmed 2018 (Clause 9) Table 2 & Amendment no.2 Aug 2007)
1	Colour	As Per RDSO	Yellowish	-
2	pH	IS 9103:1999 Reaffirmed 2018 Clause 10.1 E5	6.96	Min 6.0
3	Relative Density $20 \pm 5^\circ \text{C}$	IS 9103:1999 Reaffirmed 2018 Clause 10.1 E-3.1	1.09	Within 0.02 of value stated by manufacturer
4	Dry Material Content, %	IS 9103:1999 Reaffirmed 2018 Clause 10.1 E-1	30.12	Within 5% of the value stated by manufacturer
5	Ash content %	IS 9103:1999 Reaffirmed 2018	3.21	Within 1% of the value stated by manufacturer
6	Chloride Ion content, %	IS 6925:1973 Reaffirmed 2018	Nil	within 1.0% of value stated by manufacturer or within 0.2% of whichever is greater as stated by manufacturer
Remark: 1. Test report shall not be reproduced except in full without consent of Sttar technologies. 2. Any correction invalidation this report. 3. The results apply to the sample as received. 4. The results relate only to the items tested.				
 Aparna Patil Jr. Chemist Reviewed By		 End of Report		
		 Ashok Raut Technical Manager Authorized Signatory		
AP pagetoff		Format No: ST/FM/TR		

Customer Enquiry Email : sttartechn123@gmail.com / www.sttartechn.com / Billing Enquiry : accts.sttartechnologies@gmail.com

Material Pickup Support +91 8928557803 / Customer Care & Accounts Support +91 8828044808

MD : +91 97686 88099 / 022 6881 1510

Lab : Platinum Springs, B-6, B-101/102, Plot No. G-20 to G-24, Nr. Dena Bank, Talaja MIDC, Tal. Parvel - 410208.

UDYAM - MH-33-0155253

Reg. No. IN12648A



ISO 9001:2015