


Job Id	: TC/2504/00102-3
Test Report No.	: TCTR/2504/00102-3
Date of Report	: 16-04-2025
Name of Customer & Address	: M/s Add Chem Industries H.O: Add chem industries, 506, Prisha Apartment, Near Kamala Nehru Arcade, Gothivali, Near Rabale Railway station, Navi Mumbai-400701
Plant Address	: Plot No.: S. No.121/9, AT Village Anadi, Tal-Shahapur, Dist-Thane-421403
Customer Reference No.	: Letter Dated : 11.04.2025
Nature / Source of the sample	: Curing Compound
Sample Description/ ID Mark	: Curing Compound, ACI-CURE-ALR Based, Batch No.: 1530
Quantity	: 01 Lit
Condition of Sample	: Satisfactory
Date of Receipt of Sample	: 11-04-2025
Date of Start	: 12-04-2025
Date of Completion	: 15-04-2025

Discipline : Mechanical
Group Name: Building, Infrastructure & Construction Materials
Results And Observations :

Sr.No	Test Parameter	Test Method Used	Test Result	Permissible Limit as per ASTM C309:2019
1	Light Reflectance Test, %	ASTM E 1347:1997	68	Not less than 60%
2	Viscosity, Sec	TCS/SOP/CHEM/11, (Issue No. 01, Issue Dated: 08.06.2024	13.86	Not Specified

- Note: 1. This report is based on the sample received by our laboratory.
 2. The test result relates only to the item tested.
 3. This report shall not be reproduced, except in full, without the written permission of our laboratory.
 4. Any correction invalidates this report


Vasudev Nadi
Sr.Chemist
Reviewed by



Ashok Raut
Technical Manager
Authorized Signatory

-----End Of Report-----

Format No. : TC/FM/BM/TRC/07
 Rev :00

Page 03 of 03